

**Monmouth Ocean
Educational Services Commission**

100 Tornillo Way
Tinton Falls, NJ 07712

Analytical Results for Lead

JR Henderson Labs, Inc.
123 Seaman Ave.
Beachwood, NJ 08722
732-341-1211
Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

Monmouth Ocean Educational Services Commission
100 Tornillo Way
Tinton Falls, NJ 07712

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	LEAD RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-2750.1	Field Blank	5-26-25	09:31	<2.00	5-28-25	10:04	15
25-2750.2	TW-BF-10-125 125 Restroom	5-26-25	09:33	5.51	5-28-25	10:22	15
25-2750.3	TW-BF-10-125-Flush 125 Restroom	5-26-25	09:36	<2.00	5-28-25	10:28	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = Less Than
MRL = Minimum Reporting Limit
Lead Method 200.9-MRL 2.00

Examined By: *Margaret Ellis*
Lab Manager

Date: 5-30-25

Monmouth Ocean Educational Services Commission
100 Tornillo Way, Tinton Falls

Lead Results

	A	B	C	D	E Lab	F	G	H	I	J	K	L	M	N	O
	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1	Field Blank	N	25-2750.1	JRH Labs	15083	5/26/2025	09:31	200.9	5/28/2025	10:04	<2.00	2.00	1	N	
2	TW-BF-10-125	N	25-2750.2	JRH Labs	15083	5/26/2025	09:33	200.9	5/28/2025	10:22	5.51	2.00	1	N	
3	TW-BF-10-125-Flush	N	25-2750.3	JRH Labs	15083	5/26/2025	09:36	200.9	5/28/2025	10:28	<2.00	2.00	1	N	
4															

:Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

School Project Manager & Contact Information

Laboratory Information

NAME: Kenneth Shine

PHONE: 908-565-3997

NAME: J.R. Henderson Labs

ADDRESS & PHONE: 123 Seaman Ave, Beachwood, NJ

LAB MGR:

LAB QA DIRECTOR:

School Facility Information

SCHOOL FACILITY NAME:

Monmouth Ocean

Educational Services

Commission

MATRIX: DRINKING WATER Y/N Y

SAMPLE TYPE: GRAB Y/N Y

BLDG ID: MOESC

BLDG ADDRESS: 100 Tornillo Way, Tinton Falls, NJ, 07712

CONTACT NAME & PHONE: Ken Shine 908-565-3997

SAMPLER NAME: Ken Shine AFFILIATION: Supervisor of Buildings & Grounds DATE OF SAMPLING: 5/26/25

SAMPLE DATA FOR LEAD ANALYSIS

Sample Description ID (ID must match container label)							
Sample Location ID	Sample Outlet Location				Initial	Flush	Time of Collection
Field Blank	Field Blank				X		9:31pm
TW-BF-10-125	125 Restroom				X		9:33pm
TW-BF-10-125-Flush	125 Restroom					X	9:36pm

€ All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃):

	Print Name	Sign Name	Affiliation	Date and Time
Relinquished:	Ken Shine	<i>[Signature]</i>	SB+G	5/27/25 11:58 AM
Received By:	Vanessa Manna	Vanessa Manna	JRHL	5-27-25 11:58
Relinquished:				
Received By:				
Relinquished:				
Received By:				

Method of shipment/delivery: Fed-Ex ☒ Hand Delivery ☐ US Mail ☐ UPS ☐ Courier ☐ Other: ☐

To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY

Follow signed QAPP.

If initial first draw and follow up flush samples were collected on the same day: Yes

- Analyze initial first draw and follow up flush samples together: Y/N ☒
- Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N ☐
- Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N ☐

Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody